



STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION

**INVITATION TO BID # 32701-13303
AMENDMENT # 2
FOR HHSP SEWER LIFT REFURBISH**

DATE: April 15, 2024

ITB # 32701-13303 IS AMENDED AS FOLLOWS:

1. This ITB Schedule of Events updates and confirms scheduled ITB dates. Any event, time, or date containing revised or new text is highlighted.

Event	Time	Due Date
Event Posted	8:00 am CT	4-2-2024
Questions and Comments Due	4:30 pm CT	4-12-2024
Bids Due	2:00 pm CT	4-19-2024

2. State responses to questions and comments in the table below amend and clarify this ITB.

Any restatement of ITB text in the Question/Comment column shall NOT be construed as a change in the actual wording of the ITB document.

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		1. Would it be possible to obtain a copy of the plan holders list/bidders list for this project?	A bidders list may only be obtained during the Open File Period of this ITB, and may only be obtained by other bidders.
		2. Will there be any protective lining of structures as involved?	There are not included in the specification.
		3. Please provide all available as built documents for the existing sewer lift station.	There are no existing as-builts.
		4. Please indicate what permits contractor will be required to obtain.	Contact the City of Chapel Hill, Danny Groves.
		5. Please indicate type of valve for the buried valves specified in New Work Item #8.	Three 4-inch mechanical joint, direct bury plug valves with gear operator
		6. Please clarify if the check valves indicated in New Work Item #7 are the same check valves indicated in New Work Item #11. If not, where are these valves to be located.	They are.

ITB SECTION	PAGE #	QUESTION / COMMENT	STATE RESPONSE
		7. Please specify wire size and type for New Work Item #12.	Contractor is responsible for sizing the wire and type according to the NEC and manufacturer's recommendations.
		8. Number 14 Addendum - Please state what dimension is for Width, Length, and Depth	8-feet long, 6-feet wide, 6-feet deep with access hole. Similar to existing.

3. **ITB Amendment Effective Date.** The revisions set forth herein shall be effective upon release. All other terms and conditions of this ITB not expressly amended herein shall remain in full force and effect.